

## Certificate of constancy of performance

**0832-CPR-F0273**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **WST-PC-N00 Analogue Addressable Wall Mounted LED Strobe**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

#### **System Sensor Europe**

**Life Safety Distribution AG,  
Javastrasse 2  
CH-8604  
Hegnau  
Switzerland**

and produced in the manufacturing plant(s)

#### **KAC Alarm Company Ltd**

**Thornhill Road  
North Moons Moat  
Redditch  
B98 9ND  
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

### **EN 54-23:2010 - Visual alarm devices**

under system 1 are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 11 April 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Martin McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 11 April 2014  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).


## Appendix to Certificate of constancy of performance 0832-CPR- F0273

### Bases / Ancillaries:

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof deep back box IP33C

### Notes:

1. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details):
  - Category O: O-2.4-2
  - Flash rate 1Hz
  - Synchronization
2. *Type A with Bcc deep back box, Type B with Wcc deep back box*



Martin McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 11 April 2014  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).