

## Certificate of constancy of performance,

**0832-CPR-F1343**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **NFX-WCF-WC Analogue Addressable High Output Beacon**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

#### **Notifier by Honeywell**

**Caburn House  
2B Brooks Road  
Lewes  
BN7 2BY  
United Kingdom**

and produced in the manufacturing plant(s)

#### **KAC Alarm Company Ltd**

**Thornhill Road  
North Moons Moat  
Redditch  
B98 9ND  
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

### **EN 54-23:2010 - Visual alarm devices**

under system 1 are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 02 February 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 02 February 2016  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## **Appendix to Certificate of constancy of performance 0832-CPR-F1343**

### **Notes:**

1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details):
  - Category C: C-3-5.1, C-6-5.1, C-9-5.1
  - Category W: W-2.4-2.76
  - Flash rate 0.5Hz
  - Synchronization
2. Type A indoor use with B501AP only, Type B outdoor use with B501AP and WRR or WPW

### **Ancillaries:**

B501AP	Mounting base – Low profile base IP21C
WPW	Deep back box for outdoor (White)
WRR	Deep back box for outdoor (Red)



M McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 02 February 2016  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).