

Certificate of Product Approval

Certificate Number: 166m

Issue: 01

KAC Alarm Company Ltd

Thornhill Road,
North Moons Moat,
Redditch,
B98 9ND,
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Audible Warning Devices

WST-xC-Iyy

Standards

EN 54-17: 2005

EN 54-23: 2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Martin McCullagh

Verifier

11 April 2014

Date of Issue

11 April 2014

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 166m KAC Alarm Company Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
WST-xC-lyy	<p>Analogue addressable wall mounted LED strobe with short circuit isolator (B501AP base)</p> <p>Notes:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): <ul style="list-style-type: none"> - Category O: O-2.4-2 - Flash rate 1Hz - Synchronization Type A with Bcc deep back box, Type B with Wcc deep back box x indicates body colour. D=Detector White, P=Pure White yy indicates customer and associated communication protocol. <p>01 indicates Advanced Protocol (and Honeywell 500 series protocol) 00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol)</p>	166m/01

Bases / Ancillaries

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof deep back box IP33C

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh
Verifier

11 April 2014
Date of Issue

11 April 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 166m KAC Alarm Company Ltd

Issue: 01

Alternative Model Numbers and Labelling

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
166m/01	WST-xC-Iyy	MI-WST-PC-I	Morley-IAS Fire Systems by Honeywell (Pittway Systems Technology Group (Europe) Ltd)	166m-(cl-1)
166m/01	WST-xC-Iyy	WST-PC-I00	System Sensor Europe	166m-(cl-2)
166m/01	WST-xC-Iyy	NFXI-WF-WC	Notifier by Honeywell (Pittway Systems Technology Group (Europe) Ltd)	166m-(cl-3)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh
Verifier

11 April 2014
Date of Issue

11 April 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre