

Certificate of Product Approval

Certificate Number: 166r

Issue: 01

KAC Alarm Company Ltd

Thornhill Road,
North Moons Moat,
Redditch,
B98 9ND,
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Audible Warning Devices

WSS-xC-Iyy

Standards

EN 54-3: 2001 + A1: 2002 + A2: 2006

EN 54-17: 2005

EN 54-23: 2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Martin McCullagh

Verifier

11 April 2014

Date of Issue

11 April 2014

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 166r KAC Alarm Company Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
WSS-xC-lyy	<p>Analogue addressable wall mounted sounder / LED strobe with short circuit isolator (B501AP base)</p> <p>Notes:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): <ul style="list-style-type: none"> - Category O: O-2.4-2 - Flash rate 1Hz - Synchronization Type A with Bcc deep back box, Type B with Wcc deep back box x indicates body colour. D=Detector White, P=Pure White yy indicates customer and associated communication protocol. <p>01 indicates Advanced Protocol (and Honeywell 500 series protocol) 00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol)</p> <ol style="list-style-type: none"> Meets the requirements of EN54-3: 2001 at the following tones: <ol style="list-style-type: none"> 1) Alternating 525/440, 2Hz (100ms/400ms); 2) Alternating 800/922, 1Hz; 3) Alternating 800/922, 2Hz; 4) Alternating 2400/2900, 3Hz; 5) Alternating 2500/3100, 2Hz; 6) Alternating 988/645, 2Hz; 7) Continuous 630Hz; 8) Continuous 922Hz; 9) Continuous 1200Hz; 10) Continuous 2810Hz; 11) Sweep 150-1000Hz, rise 10s, stable 40s, fall 10s, stable 20s, then repeating; 	166r/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh
Verifier

11 April 2014
Date of Issue

11 April 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 166r KAC Alarm Company Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
	12) Intermittent 420Hz, 0.625s on, 0.625 sec off; 13) Sweep 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) Intermittent 630, 3.33Hz, 150ms on, 150ms off; 15) Intermittent 922, 0.8Hz 0.25s on, 1s off; 16) Intermittent 922, 0.5Hz 1s on, 1s off; 17) Intermittent 2810, 1Hz; 18) Intermittent 922, 1Hz 500ms on, 500ms off; 19) Intermittent 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) Continuous 800Hz; 21) Sweep 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) Sweep 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) Sweep 2400 – 2850, 7Hz; 24) Sweep 500 – 1200Hz, (0.5s off, 3.5s on); 25) Sweep 800 – 970, 50Hz; 26) Sweep 800 – 970, 7Hz; 27) Sweep 800 – 970, 1Hz; 28) Sweep 2400 – 2850, 50Hz; 29) Sweep 500 – 1000, 7Hz; 30) Sweep 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) Sweep 800 – 1000, 2Hz; 32) Sweep 2400 – 2850, 1Hz	

Bases / Ancillaries

B501AP Mounting base – Low profile base IP21C
 Bcc Deep back box
 Wcc Waterproof deep back box IP33C

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh
 Verifier

11 April 2014
 Date of Issue

11 April 2014
 Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
 T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 166r KAC Alarm Company Ltd

Issue: 01

Alternative Model Numbers and Labelling

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
166r/01	WSS-xC-lyy	MI-WSS-PC-I	Morley-IAS Fire Systems by Honeywell (Pittway Systems Technology Group (Europe) Ltd)	166r-(cl-1)
166r/01	WSS-xC-lyy	WSS-PC-I00	System Sensor Europe	166r-(cl-2)
166r/01	WSS-xC-lyy	NFXI-WSF-WC	Notifier by Honeywell (Pittway Systems Technology Group (Europe) Ltd)	166r-(cl-3)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh
Verifier

11 April 2014
Date of Issue

11 April 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre