

Certificate of Product Approval

Certificate Number: 166t-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Javastrasse 2
CH-8604
Hegnau
Switzerland



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Audible Warning Devices

WST-xC-Nyy

VAD-xC-N##

(refer to Appendix for details)

Standards

EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

19 February 2018

Date of Issue

19 February 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 166t-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

| Certified Product | Description | LPCB Ref.No. |
|-------------------|---|--------------|
| WST-xC-Nyy | <p>Analogue Addressable Wall Mounted LED Strobe (B501AP base)</p> <p>Notes:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): <ul style="list-style-type: none"> - Category O: O-2.4-2 - Flash rate 1Hz - Synchronization Type A with Bcc deep back box, Type B with Wcc deep back box x indicates body colour. D=Detector White, P=Pure White yy indicates customer and associated communication protocol. 01 indicates Advanced Protocol (and Honeywell 500 series protocol) 00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol) | 166t/01 |
| VAD-PC-N## | <p>Analogue Addressable High Output Beacon (B501AP base)</p> <p>Notes:</p> <ol style="list-style-type: none"> The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): <ul style="list-style-type: none"> - Category C: C-3-5.1, C-6-5.1, C-9-5.1 - Category W: W-2.4-2.76 - Flash rate 0.5Hz - Synchronization Type A indoor use with B501AP only, Type B outdoor use with B501AP and WRR or WPW ## indicates customer and associated communication protocol. 01 indicates Advanced Protocol (and Honeywell 500 series protocol) 00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol) | 166t/02 |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

19 February 2018

Date of Issue

19 February 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 166t-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Ancillaries

| | |
|--------|--|
| B501AP | Mounting base – Low profile base IP21C |
| Bcc | Deep back box |
| Wcc | Waterproof deep back box IP33C |
| WPW | Deep back box for outdoor (White) |
| WRR | Deep back box for outdoor (Red) |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

19 February 2018
Date of Issue

19 February 2018
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.

